

Appendix 4.10

Ventilation Noise Assessment

Appendix 4.10 Ventilation Shaft Noise Assessment

Fan Capacity	Unit	125 m3/s	(Fully Reversible)	Total
Octave Band Freq	Hz	63	125	250
Sound Power Level of the fan	dB	115	115	122
Insertion Loss of the selected silencer	dB	-12	-20	-34
A-weighting network correction		-26.2	-16.1	-8.6
Sound Power Level of the fan with silencer	dB(A)	76.8	78.9	79.4
				72.8
				67
				63.2
				67
				78.9
				85.1

Appendix 4.10 Ventilation Noise Assessment

East Ventilation Building

Louvre Ref.	Fan Type	SWL of the fan with dB(A)	
EVB 1	125m ³ /s	85.1	
EVB 2	125m ³ /s	85.1	
EVB 3	125m ³ /s	85.1	
EVB 4	125m ³ /s	85.1	
EVB 5	125m ³ /s	85.1	
EVB 6	125m ³ /s	85.1	
EVB 7	125m ³ /s	85.1	
Tonality Correction		3	
Total		96.5	

With the noise criteria = 55 dB(A),

$$\text{Log } \frac{R}{R} = \frac{(\text{SWL} - \text{SPL} - 8 + 3)/20}{67\text{m}}$$

With the noise criteria = 50 dB(A),

$$\text{Log } \frac{R}{R} = \frac{(\text{SWL} - \text{SPL} - 8 + 3)/20}{119\text{m}}$$

where R is the minimum distance between the ventilation louvres of EVB and the NSRs so as to comply with the noise criteria of 55 dB(A)

Central Ventilation Building

Louvre Ref.	Fan Type	SWL of the fan with dB(A)	
CVB 1	125m ³ /s	85.1	
CVB 2	125m ³ /s	85.1	
CVB 3	125m ³ /s	85.1	
CVB 4	125m ³ /s	85.1	
CVB 5	125m ³ /s	85.1	
CVB 6	125m ³ /s	85.1	
CVB 7	125m ³ /s	85.1	
CVB 8	125m ³ /s	85.1	
CVB 9	125m ³ /s	85.1	
CVB 10	125m ³ /s	85.1	
CVB 11	125m ³ /s	85.1	
Tonality Correction		3	
Total		98.5	

With the noise criteria = 55 dB(A),

$$\text{Log } \frac{R}{R} = \frac{(\text{SWL} - \text{SPL} - 8 + 3)/20}{84\text{m}}$$

With the noise criteria = 50 dB(A),

$$\text{Log } \frac{R}{R} = \frac{(\text{SWL} - \text{SPL} - 8 + 3)/20}{149\text{m}}$$

where R is the minimum distance between the ventilation louvres of CVB and the NSRs so as to comply with the noise criteria of 55 dB(A)

where R is the minimum distance between the ventilation louvres of EVB and the NSRs so as to comply with the noise criteria of 50 dB(A)