

**Responses-to-Comments**

**Temporary Warehouse for a Period of 3 Years in “Residential (Group B) 3” Zone, Lot 2238 S.A RP (Part) in D.D.124 and Adjoining Government Land, Hung Shui Kiu, Yuen Long, New Territories**

**(S.16 Planning Application No. A/HSK/493)**

(i) A RtoC Table:

<b>Departmental Comments</b>		<b>Applicant’s Responses</b>
<b>1. Comments of the Director of Fire Services (D of FS)</b> <b>(Contact Person: Mr. CHAU Nai-yin; Tel: 2733 7781)</b>		
(a)	The maximum storage area of a single block and the minimum clearance around the block shall be specified in the FS Notes; and	Noted. A revised fire service installations proposal is submitted by the applicant for your consideration please ( <b>Annex I</b> ).
(b)	The maximum storage heights for ST1 shall not be exceeded 4m.	