
Table | 1
Response-to-Comments

Section 16 Planning Application No. A/NE-FTA/220

Proposed Temporary Cold Storage for Poultry and Distribution Centre for a period of 3 Years with Filling of Land in "AGR" zone at Various Lots in D.D. 89 and Adjoining Government Land, Man Kam To Road, Sha Ling, New Territories

*Further Information (8)
Responses-to-Comments Table
1 November 2023*

Responses-to-Comments Table

| Date | Department | Comments | Responses |
|-----------|---|---|--|
| 1.11.2023 | Drainage Services Department (DSD) CE/MN of DSD (Contact Person: Mr. Samuel Wang; Tel: 2300 1135) | 1. Note [9] of 1st table and Note [6] of 2nd table: Please elaborate why only 2/3 of C1 is considered and advise how the remaining discharge of the sub-catchment was considered. | Based on the topography from desktop study, not all the runoff from C1 are collected into the Section 6-7 and Section 7-8. To be conservative, the calculations had been revised to include full amount of runoff from C1, the calculations show that the channel is not fully utilized and have capacity remains. See updates highlighted in blue in Appendix E |
| | | 2. Runoff from sub-catchment C3 appears to be omitted in the assessment. Please review. | Runoff in C3 is now included in the calculations. See updates highlighted in blue in Appendix E. |