

寄件者:
寄件日期: 2024年04月11日星期四 15:20
收件者: tpbpd/PLAND
副本: Gary Tat Leung LAM/PLAND; YL-TKE; Ryan Long Yin CHAN/PLAND
主旨: Application No. A/YL-MP/363 (YL-230104)
類別: Internet Email

Dear Town Planning Board,

We provide the comments for clarify the service targets of the proposed public utility installation and whether the installation is essential.

For Applicant information, the electricity power supply of applicant is Architectural Service Department..

For the justification of why installation is essential, the purpose of apply electricity power is engaged in the new public utility installation which is public toilet.

There is a relatively rare public toilet along Castle Peak Road- Mai Po, so that this new public toilet can convenient public to use.

We clarify that the standard voltage is 380V that the type of underground cable is 300 4 core AL.

Best Regards,
Manfred
Tel: